



Customer	Southern USA		Defect ranges: ⊕ 0 - 10 ● 10 - 25 ○ 25 - 50 ○ 50 - 75 ● 75 - 100	⊕ No wall loss Ⓟ Blocked Ⓟ Plugged	
Plant location					
Inspection type	ECT				
Process unit					
Equipment name	Recuperative Heater	Total tubes:	892	Plugged:	1 (<1%)
Equipment number	EX001-001	Tested:	475 (53%)	Blocked:	0 (0%)
Date	06/05/2019	0-9%:	158 (17%)		
File	EX001-001_19_06JUN	10-24%:	0 (0%)		
		25-49%:	89 (9%)		
		50-74%:	121 (13%)		
		75-100%:	107 (11%)		